

DHBVN

DAKSHIN HARYANA BIJLI VITRAN NIGAM
Office Of The Executive Engineer (OP) Division, DHBVN,
Manesar.

Pataudi Road, Kadipur, Sec-10, Gurugram-122001(Haryana)

Phone: 0124-2370030 (O)

E-mail:-xenmanesar31@gmail.com Website: www.dhbvn.com



To

The SDO 'OP' S/Divn.
DHBVN, F/Nagar

Memo No:- 5073

Date:- 01/12/2020

Subject: - Sanction of Partial load 400.000 KW against revised sanctioned ultimate load 8720 KW or CD 9689 KVA to M/s Army welfare Housing Organization sector- 95, Gurugram applied vide offline application dated 24.11.2020.

As per offline request of M/s Army welfare Housing Organization sector- 95, Gurugram, dated 24.11.2020 for Sanction of Partial load 400.000 KW against revised sanctioned ultimate load 8720 KW or CD 9689 KVA, sanctioned by SE/R-APRDP, DHBVN Hisar vide memo no. Ch-97/SE/R-APRDP/OLNC-HT/GGN-1/SOL-356, dated 07.07.2020, to meet the immediate essential requirement. The partial load 400 KW, as recommended by you vide your office email dated 25.11.2020 is hereby sanctioned on 11 KV Hayatpur RDS feeder emanating from 66 KV S/Stn. Harsaru on 11 KV supply pressure under HT BDS Supply tariff subject to fulfillment of following conditions:-

While releasing the Electricity Connection/Load/Contract Demand to the applicant, it may also to be ensured that the following statutory requirements are duly complied with in letter & spirit of the instructions of Nigam (as amended from time to time):-


- i) All the documents required to be submitted by the applicant is support of proof of ownership/legal occupation of the premises, proof of identity and other documents, prescribed under Sale Circular No. D-40/2016, are complete and dully verified in addition to the verification vide Sale Circular No.D-29/2013 dated 25.6.2013.
- ii) The load has been sanctioned as per clauses 4.5 of supply code circular vide D-26/2016. Undertaking from the applicant to adhere recovered clauses supply code regarding time line and usage.
- iii) All the provision as contained in the HERC Regulation No. HERC/29/2014 (2nd amendment) dated 8th January, 2020 (Electricity Supply Code 2014; Circulated vide Sales Circular No. D-07/2020 dated 28.03.2020 and amendments thereof are fully complied with and are strictly adhered to.
- iv) The consumer will ensure a power factor 0.90 by installing shunt capacitor (ISI Marked of compatible capacity).

- v) The percentage variation in supply voltage at the premise of the aforesaid consumer must be within the permissible limit as per Indian Electricity Rules.
- vi) The consumer will have to bear the service connection charges as per S/C No.- D-12/2020 and the amount be got deposited as per the latest instruction of the Nigam and regulatory commission.
- vii) All other formalities as required under the existing instruction are complied with.
- viii) The consumer will deposit full ACD as per sales circular No. D-12/2020 for the entire Load including security for HT tri-vector meter if the same is not supplied by the consumer.
- ix) HT Electronic Trivector meter of 3 phases 4 wires of required accuracy class and set of CTs/PTs of required accuracy class will be arranged by the firm. The CTs ratio should match to the sanctioned contract demand. The connection of CT/PT operated meter be got checked up and sealed from the M & P authorities before release of connection.
- x) The Meter room shall be provided at the main entrance gate of the premises as per instructions issued vide S/C No. D-11/2005 dated 13.7.2005 and S/I No. 7/2009 dated 2.9.2009 and installation must be got inspected by CEI before releasing the connection.
- xi) Seniority for release of connection is maintained in view of the provision contained in SMI 1.24 and provision of SMI 4.2 is adhered to in respect of site for installation of energy meter.
- xii) The consumer is not defaulter of any charges whether disputed or undisputed and there is no defaulting amount against its sister concern nor the premises is a defaulter of the Nigam.
- xiii) Electrical infrastructure is as per the CEA guideline & IE rules regarding safety precaution shall be adhered to for connecting the electrical system.
- xiv) The consumer will not raise any claim against the department for un-notified/unscheduled power cuts which are beyond the control of the department and undertaking to this effect should be obtained from the applicant/consumer.
- xv) The sanctioned load/contract demand are required to be built up within the period of six months from the release of this load as per SMI No. 21 and consumer should give an undertaking to this effect. If the consumer does not avail full sanctioned load/CD within the above period of six months, the revised A&A form for the availed load may be verified and accepted on the basis of test report which may be sent to competent authority for acceptance.
- xvi) All instructions of sales manual amended from time to time shall be applicable.
- xvii) Necessary clearance certificate from various Govt. department i.e CEI, Pollution Control Board, HSVP etc. shall be taken where ever applicable.
- xviii) No defaulting amount is pending against the consumer as its sister concern including the defaulting amount at the same premises at the date of release of connection.
- xix) The connection be released after making the compliance of all the instructions issued by the Nigam from time to time till the date of release of the connection.
- xx) Before releasing the said load, you must adhere the instruction of Nigam regarding inadequacy.

- xxi) Regarding share cost of main sub-station, applicant shall comply with the formalities as per prevailing instructions of the Nigam as well as instructions issued from time to time.
- xxii) There should be no other connection running in the same premises.
- xxiii) Applicability of any other fundamental instructions regulations of Nigam not specified above but otherwise deemed mandatory for the instant case.

This approval shall deemed to be cancelled if any of the information & fact found/noticed to be fabricated and mis-leaded at any stage, which may otherwise lead to explicit or implicit loss to Nigam, applicant shall be liable to make good such loss to Nigam. This shall however be without prejudice to the rights of Nigam to take further recourse in the matter as per the legal remedies available with the Nigam.

Documents pertaining to ownership and ACD, processing fee etc. may be check at your own level.


Executive Engineer
(OP) Manesar Divn.,
DHBVN, Gurugram.

✓
Copy to: -

M/s Army welfare Housing Organization sector- 95, Gurugram for information please.